

# **ATTENTION ALLENDALE** **TOWNSHIP RESIDENTS**

At the request of Life Stream Church, located at 6561 Lake Michigan Drive, Allendale, MI 49401 a hearing of the Construction Code Board of Appeals is scheduled for Tuesday, March 22, 2011 at 7:00 p.m. at the Allendale Charter Township Offices at 6676 Lake Michigan Drive. Life Stream Church is asking for a variance to Sections [F] 903..2.1.3 and Table 1004.1.1 of the 2006 Michigan Building Code regarding the need to install an automatic sprinkler system in a fire area of an A-3 Use Group fire area containing an occupant load of 300 or more persons. The variance requested is to allow worship services to occur in this fire area on a temporary basis until October 15, 2011.

Additional information, if needed prior to the hearing can be obtained from the Department of Planning and Community Development at the Township Office or by calling 616-895-6295 ext. 1, Monday through Friday 8:00 a.m. to 5:00 p.m.

Dept. of Planning & Community Development  
6676 Lake Michigan Drive  
P.O. Box 539  
Allendale, MI 49401  
(616) 895-6295 ext. 1

This notice is posted in compliance with PA 267 of 1976 as amended (Open Meeting Act), MCLA 41.72a (2) (3), and the Americans with Disabilities Act (ADA).

The Allendale Charter Township Board will provide necessary reasonable auxiliary aids and services, such as signers for the hearing impaired and audio tapes of printed materials being considered at the meeting, to individuals with disabilities at the meeting or public hearing upon seven (7) days notice to the Allendale Charter Township Board. Individuals with disabilities requiring auxiliary aids or services should contact the Allendale Charter Township Board by writing or calling the following:

Jerry Alkema, Supervisor  
6676 Lake Michigan Drive  
Allendale, MI 49401  
(616) 895-6295